



Westport Water Supply



S Griffin Public Meeting March 14th 2013



Outline of presentation

- Brief history of water supply
- Issues of recent times
- Asset management of existing supply and reticulation
- Strategic Review of Water Supply
- Final Options from the peer review
- Treatment Plant Upgrade Opus
- Costs



Purpose of the upgrade

- To provide a safe and secure water supply for Westport for the next 50 to 100 years
- To restore consumer confidence with a water supply that has no taste and odours
- A water supply that meets the Drinking water standards




History

- Water supply constructed 1903
- Water Treatment plant constructed 1985
- Major Upgrade to commence 2013/14









- Tunnel collapse in 2000 resulted in first strategic investigation
- Connell Wagner engaged to look at all aspects of existing supply and also other potential sources
- Risk of tunnel collapse was quantified outcome was the construction of alternative pump supply – cost about \$1m
- Water pumped from lower reaches of Orowaiti introduced algae to reservoirs – a possible source of the taste and odour



- Further tunnel collapse resulted tunnel being piped \$600,000
- Backwash failure resulted in the residual reservoir material being piped into the town reticulation.
- Second occurrence almost 12 months later



Main Replacements

- Main trunkmain varies in age
- To replace a 454mm pipe means minimal water or to some residents none at all 2003/04 10 pipes 2004/05 5 pipes 2005/06 6 pipes 2006/07 5 pipes 2007/08 7 pipes 2008/09 1 pipe 2010/11 11 pipes 2011/12 2 pipes

To some consumers these breaks occur too often.



Reticulation & Pressure

- Like the trunk main the reticulation varies with age and material
- Operates at high pressure
- Westport uses about twice as much water per capita than the average
- Combination of leakage and pressure.
- Upgrade will address pressure and possibly the replacement of the trunk main but not the reticulation.



Proposed Upgrade

- Council have revisited the Connell Wagner strategic review
- Peer reviewed by Opus
- In addition to peer reviewing the options to upgrade an operational review was undertaken of the management of the treatment plant process
- The review by Opus came back with three options
- Infiltration gallery/bore field Buller River at Te Kuha
- Infiltration gallery/bore field Buller River at Nine Mile (Reedys)
- Existing supply upgraded



Proposed Upgrade

- Council decision to upgrade the existing water supply rather than construct from different source.
- Decision was based on economics and also sustainability.
- Proposed upgrade starts at the source and reviews or renews every component progressively to the start of the reticulation




Asset Management

- Council has a GIS based asset management data base
- This is still in a development stage replacing a paper inventory
- Reticulation is plotted with material type and age
- Condition rating is an on going aspect and is evaluated at time of repairs.

Asset Management



Asset Management





Print Date: 11/03/2013 1:14,950 Scale: 1 centimeter equals 149.50 meters Cadastral information derived from Land Information New Zealand, CROWN COPYRIGHT RESERVED.

Information shown is indicative only and is the currently assumed knowledge as at date printed. If information is vita, continue with the automative owner.

Asset Management





Water Pipes Replaced Since 1970 (orange)
Print Date: 14/03/2013
Scale: 1:13,750
1 centimeter equals 137.50 meters

Cadastral information derived from Land Information New Zeatand CROWN COPYRIGHT RESERVED.

Information shown is indicative only and is the currently assumed knowledge as at date printed. If information is vital, confirm with the authorative owner.










Westport Water Treatment Plant Upgrade


Introduction

- Westport drinking-water supply A unique supply with unusual features
- Why is an upgrade needed?
- What will the upgrade consist of?






























Existing system



Why is an upgrade needed?


- There have been some problems with water quality from the treatment plant
- We know a lot more about water supply contaminants than we did in 1986



- Water treatment technology has improved considerably
- Legislation introduced in 2007
- Drinking water standards




Raw water ponds bypass




Raw water ponds by-pass




Turbidimeter




Flocculation tanks




Powdered carbon




Filter backwash storage




UV disinfection



New treated water storage reservoir



Filter to waste and pressure management



Upgrade consists of

- Raw water pond bypass
- Flocculation tanks
- Powdered carbon
- Backwash storage
- UV disinfection



- New treated water storage reservoir
- Filter to waste and pressure management



Timeframes

- Detailed design completed April 2013
- Tenders evaluated June 2013
- Construction begins

September 2013

• Bulk of works completed September 2014





Staged upgrade included in Long Term Plan

| 2012/13 | \$26,700 | Planning, legal & property | 2016/17 | \$1,350,000 | Enlarge raw water ponds | |
|---------|-------------|--|---------|--------------|---|--|
| | \$130,000 | Raw water quality | 2018/19 | \$1,500,000 | Pipe rest of tunnels | |
| | | management | 2020/21 | \$2,887,000 | Replace trunk main | |
| | \$700,000 | Flocculation tanks | 2022/22 | \$2,400,000 | Construct treated water | |
| | \$856,700 | | 2022/23 | | reservoirs | |
| 2013/14 | \$521,000 | Filter refurbishment | | \$610,000 | Line raw water reservoirs | |
| | | Seismic strengthen | | \$11,951,200 | Cost estimated in 2012 \$ | |
| | \$260,000 | Filtered water back wash storage | 2023/24 | \$14,670,329 | Cost in LTP adjusted for inflation (BERL Factors) | |
| | \$170,000 | Filter to waste system | | \$2,719,129 | Inflation | |
| | \$951,000 | | | | | |
| 2014/15 | \$413,000 | New plant building monitoring & control | | | | |
| | \$393,500 | UV disinfection & buildings | | | | |
| | \$215,000 | Alkalinity correction system | | | | |
| | \$375,000 | By Pass raw water ponds | | | | |
| | \$1,396,500 | | | | | |



Financial Impact Three options:


1.Full upgrade at a cost of \$10.3 million defers tunnel piping & lining raw water reservoirs.

2.Part upgrade at a cost of \$8.9 million as above but also defers cleaning ot raw water reservoirs

3.Minimum upgrade at a cost of \$5.8 million as above but also defers replacing trunk main.


Upgrade Expense Comparison

BULLER



Effect on Westport Targeted Rates

BULLER





Effect on Westport Targeted Rates

| Westport Targeted Rates (GST Exclusive) | | | | | | | | | | |
|---|-------|-------|-------|-------|-------|-------|-------|-------|-------|--|
| | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | |
| Full Upgrade | \$580 | \$720 | \$790 | \$850 | \$870 | \$890 | \$900 | \$900 | \$910 | |
| Part Upgrade | \$580 | \$710 | \$760 | \$800 | \$820 | \$840 | \$860 | \$870 | \$880 | |
| Minimum Upgrade | \$580 | \$690 | \$720 | \$740 | \$740 | \$750 | \$760 | \$780 | \$790 | |
| | | | | | | | | | | |

